

# Controlling Carbonate Buildup in Pneumatic Hydrate Injection Systems-

**Martin Dillon, P.E., PMP & Gregory Filippelli, P.E.**  
*Co-Authors: Cameron Martin, and Aaron Oakley, ADA-ES*

**EUEC Energy & Environment Conference**  
**February 2, 2011**

**NASDAQ:ADES**  
*A Leader in Clean Coal Technology*




# Overview

- Introduction & Summary
- Chemistry and Reactivity Considerations
- Design & Operational Challenges
- ADA Hydrated Lime Injection System Design Approach.

# Carbonate Formation in Hydrated Lime Injection Systems



- Hydrated lime reacts with Carbon Dioxide (CO<sub>2</sub>) at ambient concentrations.
- Hydrated lime reacts with CO<sub>2</sub> to form calcium carbonate, (CaCO<sub>3</sub>) and water (H<sub>2</sub>O).



- To avoid scale, either remove the CO<sub>2</sub> or control the reaction.

# Carbonate Formation in Hydrated Lime Injection Systems (Cont.)

- Targeted Reactions:



- To promote optimum acid gas mitigation & reagent utilization - lime reactions *should* occur in the duct.
- Minimize*  $\text{CaCO}_3$  formation in conveyance system
  - Deliver more effective reactant to the duct (lime v. carbonate) .
  - Decrease carbonate system scaling.
  - Increases system reliability.

# Carbonate Formation in Hydrated Lime Injection Systems (Cont.)

- Carbonate formation is thermodynamically-dependent
  - At ambient temperature and atmospheric concentrations,  $\text{CaCO}_3$  formation is moderated.
  - Once fluid temp  $> 95^\circ\text{F}$  the  $\text{CaCO}_3$  formation increases.
  - Once fluid temp  $> 120^\circ\text{F}$  the rate of carbonate formation is believed to accelerate

# Carbonate Formation in Lime Injection Systems (Cont.)

- Temperature is important in determining the carbonate morphology (speciation).
- $\text{CaCO}_3$  can differ in crystalline structure and 'morphology'.
- Maintaining system temperatures appropriately low keeps  $\text{CaCO}_3$  formation away from the *bad* polymorphs which minimizes scale production and buildup

# System Design & Operational Challenges

- Operational consideration
  - Motive air source for most pneumatic systems is ambient air that is compressed by a regenerative or positive displacement blower.
  - Compression inefficiencies result in heat being added to the air versus compression work.
- Required reactants ( $\text{CO}_2$ ,  $\text{Ca}(\text{OH})_2$  and heat) now available and favorable for  $\text{CaCO}_3$ .

# System Design & Operational Challenges

- CO<sub>2</sub> is essentially an unavoidable consequence of using ambient air for motive air.
- Inject the lime as lime not carbonate
  - CaCO<sub>3</sub> is less reactive than Ca(OH)<sub>2</sub>.
  - CaCO<sub>3</sub> polymorphs *can be* abrasive.
  - CaCO<sub>3</sub> polymorphs *can be* sticky which have a greater scaling potential as they dehydrate and/or heat .

# System Design & Operational Challenges

- Presence of moisture further complicates conveyance system performance because:
  - $\text{Ca(OH)}_2$  is hygroscopic and will absorb water ultimately changes handling characteristics ( $\uparrow$  density).
  - $\uparrow$   $\text{CaCO}_3$  related abrasion & agglomeration issues.
- These effects seem to be additive and promote component scaling, material accumulation, and eventual system failure.


# System Design & Operational Challenges

- System design that promotes the targeted chemistry and limits the by-product chemistry.
- CO<sub>2</sub> issue is part of the ambient air but we can eliminate its impact by reducing heat input.
- Distribution considerations.

# Hydrate Systems

- Two general Hydrated Lime Injection System (HLIS) configurations:
  - 1<sup>st</sup> based on an equipment arrangement that works well for a lot of applications
  - 2<sup>nd</sup> based on a new equipment configuration through Mississippi Lime Company (MLC).
- ADA configuration is designed to address the  $\text{Ca}(\text{OH})_2$  reactivity issues.


# Hydrate Delivery System Design Option 1



# Hydrate Delivery System Design Option 1 (Cont.)

- Recent operating experience with this equipment arrangement suggests:
  - Inlet dehumidifiers are not always effective.
  - After cooler downstream the blower seems to have the most impact.

# Hydrate Delivery System Design Option 2 – MLC (Cont.)



# Hydrate Delivery System Design Option 2 – MLC (Cont.)

- While this design has demonstrated performance improvements – by chemistry this approach possesses limitations.
- For the CO<sub>2</sub> to be scrubbed the air supplied by the fluidizing system needs to be **hot**.
  - Speciation becomes a concern.
- CO<sub>2</sub> removal likely dependent on the silo material level.


# Hydrate Delivery System Design Option 2 – MLC (Cont.)

- $\text{CaCO}_3$  still produced - according to MLC the expected occlusion duration is ~220 days.
- Another limitation this approach is  $\text{CO}_2$  removal would most likely be variable with the material level in the silo.

# Hydrate Delivery System Design Option 3 – ADA

- CO<sub>2</sub> & heat are issues with previous approach.
  - Scale prevention should include temperature and moisture control of the entire conveyance system.
- ADA approach involves 3 design criteria:
  - 1.) maintaining the conveyance air at lower temperatures
  - 2.) reducing moisture levels in the conveyance air, and
  - 3.) appropriate conveyance velocities.
- The ADA design philosophy can be summarized as: *'keep it cool, keep it dry, keep it slow™.'*


# Hydrate Delivery System Design Option 3 – ADA



# Hydrate Delivery System Design Option 3 – ADA (Cont.)

- Using cool dry expanded compressed air has some distinct advantages:
  - Constant volume.
  - Since alkaline sorbents are hygroscopic, air moisture content is principal to overall system performance and for enduring operation.
- Related to air dryness & moisture content is the ability of the dry air to be a superior insulator
  - Since the compressed air system provides dryer air, it has less ability to carry & transfer heat to its surroundings
  - Consequently the air cannot transfer heat to the hydrate further facilitating scale prevention.

# Hydrate Delivery System Design Option 3 – ADA



# Hydrate Delivery System Design Option 3 – ADA (Cont.)

- Dry compressed air is supplied to the air supply side at the metering point.
- Near the manifold, the compressed air expands to the design pressure of the dilute phase pneumatic conveyance system
  - The precisely metered air is allowed to expand adiabatically.
  - This expansion achieves a net cooling effect which further facilitates reducing system temperature.

# Hydrate Delivery System Design Option 3 – ADA (Cont.)

- When conveying at slower velocities material tends to more closely follow the bulk air flow.
- Slow conveying velocities are key to preventing excessive material impingement and therefore abrasion erosion of injection components.
- To allow continued & reliable operation at lower velocities, ADA developed a manifold which allows material to follow conveyance air and assure the designed distribution is maintained.

# Hydrate Delivery System Design Option 3 – ADA (Cont.)

- ADA system success attributed too:
  - Avoiding the formation of the harder aragonite carbonate species.
  - Using lower conveying temperatures.
  - Slower conveying velocities to minimize material self-heating, impingement, and turbulence.
- Post-mortem inspection of the injection system internals following testing-scale operations has not revealed component wear.

# Summary

- Accounting for chemistry is critical to system performance.
- The choices are to control...
  - the reactants or
  - the reactions
- ADA's approach is to hydrate injection is “Keep it cool, keep it dry, keep it slow”™



# Thank You

Martin Dillon, ADA-ES  
martyd@adaes.com  
(303) 734-1727

